
CERTIFICATE OF APPROVAL

No CF 5503

This is to certify that, in accordance with
TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

CONSORT ARCHITECTURAL HARDWARE LTD


29-31 Lower Loveday Street, Birmingham,
B19 3SB, United Kingdom
Tel: 0121 359 8189

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

CERTIFIED PRODUCT
CDC700, CDC750 and CDC903
Overhead Door Closers

TECHNICAL SCHEDULE
TS 34 - The Contribution Of
Controlled Door Closing
Devices And Accessories To
Fire Resisting Doorsets

Signed and sealed for and on behalf of Exova (UK) Limited trading as
Warrington Certification



Sir Ken Knight
Chairman
Impartiality Committee



Paul Duggan
Certification Manager



Issued: 1st March 2017
Valid to: 28th February 2022

Page 1 of 6



CERTIFICATE No CF 5503

CONSORT ARCHITECTURAL HARDWARE LTD

Consort CDC700, CDC750 and CDC903 surface mounted overhead door closer

1. This approval applies to Consort rack and pinion overhead door closer models CDC700, CDC750 and CDC903, but excludes any mechanical hold open variants. All closers have a backcheck (BC) option, the CDC750 also has an optional delayed-action (DA) function. The approval applies to the following configurations:

	CDC700	CDC750	CDC903
Link-arms			
Projecting arm (Fig. 1) <i>Body door mounted on pull face</i>	✓	✓	✓
Projecting arm (Fig. 61) <i>Body transom mounted on push face</i>	✗	✗	✗
Parallel arm (Fig. 6) <i>Body door mounted on push face</i>	✓	✓	✗
Slide arms			
Body door mounted on pull face	✗	✗	✗
Body transom mounted on push face	✗	✗	✗
Body door mounted on push face	✗	✗	✗
Body transom mounted on pull face	✗	✗	✗

Key: ✓ - approved ✗ - Not approved

Note: Where alternative arms for non-fire applications are included within the packaging, the use of these components on fire resisting door assemblies will invalidate the certification.

2. This approval relates to its use with the following door assemblies: -

Latched and unlatched, intumescent sealed door assemblies consisting of timber faced and edged leaves with timber, cellulosic or mineral cores in timber frames having a fire resistance up to 120 minutes (CERTIFIRE Code ITT).

Latched and unlatched, door assemblies consisting of fully insulated metal door assemblies in metal frames with or without intumescent seals having a fire resistance up to 240 minutes (Code IMM/MM).

CERTIFICATE No CF 5503
CONSORT ARCHITECTURAL HARDWARE LTD

Consort CDC700, CDC750 and CDC903 surface mounted overhead door closer

3. This certification is designed to demonstrate compliance of the product or system specifically with Approved Document B (England and Wales), the Technical Handbooks (Scotland) and Technical Booklet E (N. Ireland). If compliance is required to other regulatory or guidance documents there may be additional considerations or conflict to be taken into account.
4. The closer is approved on the basis of:
 - i) Initial type testing to EN1154 and BS EN 1634-1.
 - ii) An appraisal against TS34
 - iii) Inspection of quality management system
 - iv) Inspection and surveillance of factory production control
 - v) Ongoing audit testing in accordance with EN 1154 requirements
5. This approval is applicable only to the specified closers when mounted in the applications stated above and under the classification codes section of this certificate and used with door assemblies of proven fire resistance (as defined in BS EN 1634-1 or BS 476: Part 22: 1987) and having power ratings appropriate to the leaf sizes subject to a minimum size 3 (as specified in BS EN 1154).
6. The approval relates to ongoing production. Product and/or its immediate packaging is identified with the manufacturer's name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.

CERTIFICATE No CF 5503

CONSORT ARCHITECTURAL HARDWARE LTD

Consort CDC700, CDC750 and CDC903 surface mounted overhead door closer

7. The following table show acceptable doorset types and fire resistance periods:

Class	Approved Door Type				
	IMM	MM	ITT	ITM	ITC
FD20	✓	✓	✓	✗	✗
FD30	✓	✓	✓	✗	✗
FD60	✓	✓	✓	✗	✗
FD90	✓	✓	✓	✗	✗
FD120	✓	✓	✓	✗	✗
FD240	✓	✓	✗	✗	✗
E 20	✓	✓	✓	✗	✗
EI 20	✓	✓	✓	✗	✗
E 30	✓	✓	✓	✗	✗
EI 30	✓	✓	✓	✗	✗
E 60	✓	✓	✓	✗	✗
EI 60	✓	✓	✓	✗	✗
E 90	✓	✓	✓	✗	✗
EI 90	✓	✓	✓	✗	✗
E 120	✓	✓	✓	✗	✗
EI 120	✓	✓	✓	✗	✗
E 240	✓	✓	✗	✗	✗
EI 240	✓	✓	✗	✗	✗

Key:

- ✓ - approved
- ✗ - Not approved

Note: closers are only approved for use on IMM/MM doorsets that are fully insulated for the full classification period required.

CERTIFICATE No CF 5503

CONSORT ARCHITECTURAL HARDWARE LTD

Consort CDC700, CDC750 and CDC903 surface mounted overhead door closer

8. Doors are classified as the following types:

Type MM - 20 minute to 240 minute doorsets that consist of metallic leaves in metallic frames that do not contain intumescent materials in the frame to leaf gap.

Type IMM - 20 minute to 240 minute doorsets that consist of metallic leaves in metallic frames that contain intumescent materials in the frame to leaf gap.

Type ITT - 20 minute to 120 minute doorsets containing intumescent seals and consisting of non-metallic faced and edged leaves hung in timber frames

Type ITM - 20 minute to 120 minute doorsets containing intumescent seals and consisting of non-metallic faced and edged leaves hung in metal frames.

Type ITC - 20 minute to 120 minute doorsets containing intumescent seals and consisting of non-metallic faced and edged leaves hung in proprietary composite frames, of which the principal material is other than timber or metal but which may include any other materials.

Scope of Approval:

- All applications apply to unglazed doorsets and glazed doorsets incorporating an uninsulated glass panel size of less than 20% of the leaf area.
- The closer application is as referenced in the Classification code section below in accordance with EN 1154.

Classification codes:

CDC700 and CDC700BC Figure 1 projecting arm applications

4	8	4 3	1	1	3
---	---	--------	---	---	---

CDC700 and CDC700BC Figure 6 parallel arm application

3	8	4	1	1	3
---	---	---	---	---	---

CERTIFICATE No CF 5503

CONSORT ARCHITECTURAL HARDWARE LTD

Consort CDC700, CDC750 and CDC903 surface mounted overhead door closer

Classification codes – cont'd:

CDC750, CDC750BC and CDC750DA Figure 1 projecting arm applications

4	8	5 3	1	1	3
---	---	--------	---	---	---

CDC750, CDC750BC and CDC750DA Figure 6 parallel arm applications

3	8	5 3	1	1	3
---	---	--------	---	---	---

CDC903 and CDC903BC Figure 1 projecting arm applications

4	8	6 3	1	1	3
---	---	--------	---	---	---

Further Information

Further information regarding the details contained in this certificate may be obtained from Consort Architectural Hardware Ltd (Tel: 0121 359 8189).

Further information regarding CERTIFIRE certification and other approved products can be obtained from CERTIFIRE (Tel: 01925 646777).