



CERTIFICATE OF APPROVAL

No CF 5732

This is to certify that, in accordance with
TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

Consort Architectural Hardware Ltd.
25- 31 Lower Loveday Street , Birmingham,
B19 3SB
Tel: 0121 359 8189

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

CERTIFIED PRODUCT

Consort Intumescent door seals
(with optional smoke seals)

TECHNICAL SCHEDULE

TS35 – The Contribution Of
Intumescent Seals To The Fire
Resistance Of Pedestrian Type
Door Assemblies (Issue 2)

TS21 – The Contribution of
Edge Seals to the Control of
Smoke Leakage via Door
Assemblies

Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited

Paul Duggan
Certification Manager

Issued: 3rd July 2019
Valid to: 27th June 2021



CERTIFICATE No CF 5732

Consort Architectural Hardware Ltd

CONSORT INTUMESCENT DOOR SEALS WITH OPTIONAL SMOKE SEALS

1. Rigid Seals

Consort intumescent seals comprise a range of PVC-encased, graphite based intumescent seals with or without integral smoke seals. The seals are supplied with a self-adhesive backing in a range of different colours and lengths. This approval applies to the described seals of minimum dimensions 10 mm wide by 4 mm thick (for 30 minute applications) and minimum dimensions 15mm wide by 4mm thick (for 60 minute applications) or larger in all variations of finish both with and without integral seals. The following table gives examples, however they are not absolute:

Profile Dimension	Type
10 x 4mm	Fire Only
15 x 4mm	Fire Only
20 x 4mm	Fire Only
25 x 4mm	Fire Only
10 x 4mm	Fire and Smoke
15 x 4mm	Fire and Smoke
20 x 4mm	Fire and Smoke
25 x 4mm	Fire and Smoke

For further information please refer to the Consort product data sheet.

Flexible Seals

Consort flexible intumescent seals are a graphite only seal supplied with a self-adhesive backing in various lengths that are designed for fire only applications. The following table gives examples, however they are not absolute:

Profile Dimension	Type
10 x 2mm	Fire Only
15 x 2mm	Fire Only
20 x 2mm	Fire Only
25 x 2mm	Fire Only
30 x 2mm	Fire Only

For further information please refer to the Consort product data sheet.



CERTIFICATE No CF 5732

Consort Architectural Hardware Ltd

CONSORT INTUMESCENT DOOR SEALS WITH OPTIONAL SMOKE SEALS

2. The door seals are approved on the basis of:
- i) A design appraisal against TS35 and TS21
 - ii) Initial type testing
 - iii) Manufacturing frequency checks
 - iv) Ageing and durability tests
 - v) Evidence of technical support
 - vi) Clear and unambiguous labelling of seals
 - vii) Certification of quality management system to ISO 9001: 2008.
 - vii) Inspection and surveillance of factory production control
 - viii) Ongoing audit tests in accordance with TS35
3. These seals, of minimum dimensions 10 mm wide by 4 mm thick, are suitable to be used with:
- CERTIFIRE approved FD30 single-acting, single leaf, latched or unlatched doorsets of maximum leaf dimensions 2040 mm high by 926 mm wide and of minimum thickness 42 mm. The doorset assemblies shall consist of timber faced and edged leaves with timber, cellulosic or mineral cores in timber frames (Code ITT). More information can be referred to in TS35.***
4. The suitability of the seals in door assemblies not certificated by CERTIFIRE should be established by reference to the certification, test reports or assessments relating to the particular door assembly.
5. Consort graphite based intumescent seals may be used with doorsets outside of the scope given above (paragraph 3) providing the door manufacturer's certification shows acceptability.
6. **These seals are suitable to be used with CERTIFIRE approved single or double leaf, FD30, FD60, FD90 and FD120 doorsets or previously tested (in accordance with BS 476: Part 22: 1987), which have been specifically tested with this type of seal. The seal size and configuration required in the relevant CERTIFIRE certificate or test report must be replicated. The doorset assemblies shall consist of timber faced and edged leaves with timber, cellulosic or mineral cores in timber frames (Code ITT).**



CERTIFICATE No CF 5732

Consort Architectural Hardware Ltd

CONSORT INTUMESCENT DOOR SEALS WITH OPTIONAL SMOKE SEALS

7. The approved Consort seals shall have nominal widths and cross-sectional areas of intumescent at least equal to those in the tested/approved door assembly and shall be similarly positioned.
8. This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
9. The seals shall be installed in accordance with the manufacturer's instructions.
10. The approval relates to on going production. Product and/or its immediate packaging is identified with the manufacturers' name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number (i.e. No.CF 5732) and application where appropriate.